

<b>POWER PLANT STACK</b>					
Month	Particulate matter (mg/Nm <sup>3</sup> )			SO <sub>2</sub> (mg/Nm <sup>3</sup> )	NO <sub>2</sub> (mg/Nm <sup>3</sup> )
	Boiler -1	Boiler -2	Boiler -3		
Oct'14	63	--	83	276/291	88/93
Nov'14	81	--	89	285/296	91/96
Dec'14	74	82	--	294/306	88/94
Jan'15	81	87	--	291/283	95/87
Feb'15	--	63	74	280/287	85/91
March'15	--	81	86	310/290	97/89

