

POWER PLANT STACK					
Month	Particulate matter (mg/Nm ³)			SO ₂ (mg/Nm ³)	NO ₂ (mg/Nm ³)
	Boiler -1	Boiler -2	Boiler -3		
October'13	82	--	--	296	88
November'13	76	--	87	290/310	78/75
December'13	89	69	--	290/288	90/80
January'14	82	--	73	257/271	98/89
February'14	78	71	--	298/291	104/95
March'14	86	81	--	302/292	90/86