

POWER PLANT STACK					
Month	Particulate matter (mg/Nm³)			SO₂ (mg/Nm³)	NO₂ (mg/Nm³)
	Boiler -1	Boiler -2	Boiler -3		
Apr-16	Maintenance	71	76	294/299	93/98
May-16	74	78	Maintenance	282/288	97/102
Jun-16	77	81	Maintenance	310/299	98/96
Jul-16	82	Maintenance	86	302/306	104/110
Aug-16	83	Maintenance	88	306/314	113/118
Sep-16	81	Maintenance	76	318/287	95/93